

25X1A Chief, [REDACTED]

25X1A Chief, [REDACTED]

25X1A Engineering - Design Information for [REDACTED] R-2 Site

REF: A. [REDACTED] dated 13 December 1968
B. [REDACTED] dated 22 November 1968 25X1A
C. [REDACTED] dated 5 December 1968


25X1A 1. The updated Scope of Work, and generator and switchgear details will be pouched shortly. The "Sequence of Operation" attached to Ref. A was not requested and will not apply, the switchgear instructions will replace it. We regret the apparent misunderstanding on the subject.

25X1A 2. Enclosed are details on the self-supporting tower, Lockable Grillwork and the "Computer Floor" [REDACTED] Interface. 25X1A

25X1A

25X1A

SECRET



13 January 1969 SCD/FEB [REDACTED] ep 25X1A

2936

Distribution:

- 1 - OC-RMS
- 1 - OC-ES OL/RECD
- 1 - OL/RECD
- 1 - OC-SCD
- 1 - FEB File
- 1 - FEB Chrono

3 FEB 1969
RECORDED
OL REGISTRY

~~SECRET~~

[REDACTED] 25X1A

7. The self-supporting tower should be located as close as permissible to the building. We have studied Ref. C and need to know the height of the link antennas at the T-Site. We plan to use a new 900 MC link system if Fresnel Zone clearances are acceptable.

8. The 9' x 9' window in the personnel control door between Rooms 106 and 121 does not require visual security as it is between two controlled areas.

9. The high efficiency air filters can be deleted.

10. Foot valves with strainers are required on the Diesel Generator fuel intakes in the day tank. Day tank should be approximately 100 gallon capacity.

11. Attachment No. 1 is a list of all applicable drawings for this project. Attachment No. 2 is a set of reproducible drawings for the [REDACTED]

25X1A

12. In case of conflicts between our drawings and previous comments on A&E drawings, Ref. B Attachment I, the Ref. B comments would apply.

[REDACTED] 25X1A

Att:

1. List of Current Drawings (1 copy)
2. Set of Reproducible Drawings (1 set)
3. 2 Sets of Drawings (2 sets)
4. Details on Self-Supporting Towers (4 copies)
5. Computer Floor Interface Details (4 copies)
6. Lockable Grill Details (4 copies)

Distribution:

3 - Chief, [REDACTED]

25X1A

14 JUN 78 10 03 AM

~~SECRET~~